

IC REJECTION LETTER

No. CBSE/AFF/SL-00642-2425/2024-25

Dated:11/01/2024

The Manager,
AVP GLOBAL SCHOOL KISHORE CAMPUS PLOT NO 309 -310-3 JALGAON JAMOD ROAD
KHADKOD
BURHANPUR
BURHANPUR , MADHYA PRADESH
450331

Sub: Category of school applied for (**Fresh Affiliation Up to Secondary Level**) -regarding.

Ref: Application No.SL-00642-2425 dated 30/06/2023

This is with reference to school application No.SL-00642-2425 dt.30/06/2023 on the subject cited above

In this connection, I am directed to inform that your application has been rejected on the following grounds.

1	The school has overlaid a ramp over a staircase to access the upper floors, hence it is very steep and unsafe for navigation by CWSN and is not as per norms of RPwD Act and guidelines issued by the Board. Ramp at entrance is not seen.
---	--

2	The school has not constructed separate toilets for CWSN, boys and girls on every floor with proper permanent signage as per norms of RPwD Act and guidelines issued by the Board.
3	The school does not have concrete boundary wall from all sides with uniform minimum height of 6 feet(Ref IC vide 1.26). In some places, iron net is fixed on concrete wall for making the height 6 feet or so.
4	Composite lab does not have lab standard tables. Only one workstation is seen. It is under stocked with little equipment placed on tables. The tables are arranged on the side wall which is not appropriate. It is not fit for conducting experiments, as it does not have separate work stations with inbuilt utilities for bio and chemistry sections and no tables with equipment for physics section. No seating and safety features(exhust fan, emergency exit etc)are seen. Storage facility is not sufficient.
5	Math lab is a temporary arrangement, with equipment is displayed on tables and is a collection of few equipment/kits. It does not have work spaces for students with appropriate furniture.
6	Number of Computer is insufficient as per CBSE circular no 10/2023 dated 24.03.2023
7	School has affixed temporary paper signage at prominent places like classrooms, library, toilets, labs etc.
8	Library is poorly stocked in terms of numbers and variety of books. As per report of IC, Librarian is not appointed as per norms. Stock register is not properly maintained.

Further, as per clause 10.5.2 of Affiliation Bye-Laws, 2018, the fee deposited will not be refunded or adjusted irrespective of the grounds on which the application has been rejected even if the school has not been inspected.

1/11/24, 4:02 PM

about:blank

The school may seek a review of the above decision of the Board within 15 days on SARAS portal.

DEPUTY SECRETARY/JOINT SECRETARY (AFF.)

This is an electronically generated document. It does not need any signature.

To verify the authenticity of the document , please visit

(<http://www.saras.cbse.gov.in/saras/AffiliatedList/ListOfSchdirReport>).

Print